

# An RF beam Sweeper for Purifying In-Flight Produced Rare Isotope Beams

PI: Alexander Yu. Smirnov, Ph.D. DOE SBIR Award DE-SC0019719 DOE NP SBIR/STTR Phase II PI Exchange Meeting, August 25, 2022 RadiaBeam



- Founded in 2004
- ~50 employees and growing
- 30,000 ft<sup>2</sup> headquarters in Santa Monica, CA



 Accelerator R&D, design, engineering, manufacturing and testing all under one roof in a dynamic, small-business setting



#### Machine Shop



- Multiple CNC milling and turning centers, > \$3 million investment
- Dedicated "clean shop" for RF and UHV machining
- Full-suite of inspection equipment, including CMM
- 10 highly-skilled machinists
- ISO 9001 compliant quality system













- Secondary radioactive beams are produced when a primary beam hits the target
- Other low-energy isotopes are produced during this process
- The isotopes different from the required isotopes must be filtered






- In ATLAS, a chicane magnetic fragment separator is used to filter the unwanted isotopes, as some isotopes can still pass through this separator
- Velocity selection criterion is needed





#### An existing RF sweeper provides with 55kV kick at 6 MHz (~1 kW input power)





#### New sweeper parameters – Version A



. \/


- The deflecting voltage should be 3x higher than the existing ATLAS separator (which is 55 kV at 6 MHz)
- The dimensions are limited to 1 m
- It was proposed to increase the frequency by factor of 2 and overlap RF deflection with DC bias to achieve the same deflection as pure 150 kV RF kick at 6 MHz


- Cosine instead of sine

		Existing 🛉	V
Fragment purity improvement	>5 times		$E_0*sin(\omega t)$
Operating frequency	12 MHz	En la	
Deflecting voltage	150 kV (75kV		6 MHz Sine
	from RF and 75	Proposed 🔵 🥌	V E <sub>0</sub> *(cos(2ωt)-1)
	kV from DC)		
Secondary beam energy	3-10 MeV/u		$\langle \rangle / \langle \rangle$
Charge-to-mass ratio	varies	$\bigvee$ $\bigvee$ $\downarrow$	$\bigvee$
Aperture	10 cm	1	2 MHz cosine + DC

#### Version A parameters and design

 We designed a 12 MHz sweeper based on 'lumped' elements that allows 75 kV RF kick + 75 kV DC kick





liaBeam

Fundamental frequency	12.125 MHz
Deflecting voltage	150 kV
RF power	2.6 kW
DC bias	75 kV
Length	1 m
Aperture (gap)	10 cm

#### New sweeper parameters – Version B




- Cosine wave deflector's zero point is at the crest, it is very much non-linear around it and doesn't provide a good separation
- We proposed to redesign the kicker to provide purely RF kick of 150 kV that can operate at 2 frequencies: 6 MHz and 12 MHz for different ion species.
- The frequency should be manually switched between the experiments in ~hours timeframe.

Fragment purity improvement	>5 times	<5 MeV/u E <sub>0</sub> *sin(ωt)
Operating frequency	6 MHz and 12 MHz	
Deflecting voltage	150 kV	6 MHz Sine t
Secondary beam energy	3-10 MeV/u	>10 MeV/u ►0*sin(2ωt)
Charge-to-mass ratio	varies	
Aperture	7.5 cm	
		12 MHz Sine

#### <sup>10</sup> Principal schemes to allow dual-frequency operation




Vacuum Tank



• In-vacuum switch:

 Problem to connect RF and water inside vacuum volume



- Sliding contact:
  - Problem to connect RF and water inside vacuum volume
  - Very large coil

• Ground switches:

Ŀ,

• Allows water flow thru both electrodes

CTT TTTT


• RF leakage

6 MHz

12 MHz

#### <sup>11</sup> Version B parameters and design

 We designed a new sweeper based on 'lumped' elements that allows two operation regimes each providing with 150 kV kick




Frequencies	6 + 12 MHz
Deflecting voltage	150 kV
RF power	~9 kW
Length	1 m
Aperture (gap)	7.5 cm


iaBeam


### <sup>12</sup> Version B parameters and design




#### 6 MHz mode










Parameter	6 MHz	12 MHz
RF power for 150 kV	8100 W	9850 W
Coil dimensions	Coil 1: 7 periods, D=290 mm, H=455 mm, Coil 2: 4.5 periods, D=232 mm, H= 292.5 mm	Coil 2: 4.5 periods, D=232 mm, H= 292.5 mm
Coil pipe ID/OD	29 mm/35 mm	
Vacuum tank	L×W×H 1280 mm × 750 mm× 1000 mm	
Ground legs pipe ID/OD	44 mm/50 mm	
Кр	4.7 MV/m	5.7 MV/m
Peak E (150kV)	5.37 MV/m	5.43 MV/m
Peak E (150kV)/Kp	1.14	0.95



### <sup>13</sup> Thermal study



°C

78.5

74-

70-

62 -


58-

54-

50 -


42 -


38 -34 -30 -



## <sup>14</sup> Engineering design








### <sup>15</sup> Engineering design




Sliding switch Female switch end Male switch end Compliant bellows assembly Angular port aligner Linear stage. Manual transversal movement, motorized vertical axis.

#### Pipe-in-pipe cooling



#### <sup>16</sup> Solid-state RF source

- We designed and tested 12 MHz Class-E solid-state power amplifier
- Achieved ~1kW power at 82% efficiency
- The design for 2 kW pallet is ready and is currently in production



diaBeam