

NATIONAL ENVIRONMENTAL POLICY ACT (NEPA)
RECORD OF CATEGORICAL EXCLUSION DETERMINATION

A. Brief Description of Proposed Action:

The Critical Utilities Rehabilitation Project (CURP) at Brookhaven National Laboratory includes replacement and/or upgrades and improvements to the electrical distribution system, chilled water supply, steam generation and distribution system, potable water supply, and sanitary collection and sewage treatment system. The project includes but is not limited to replacement of water mains, steam and condensate piping, and steam generating and chiller components, installation of new electrical feeder cables and an automatic chemical feed system at the sewage treatment plant.

Number and Title of the Categorical Exclusion Being Applied:

B1.3 Routine Maintenance, B1.5 Existing steam plants and cooling water systems, B1.15 Support buildings, and B2.5 Facility safety and environmental improvements.

B. Regulatory Requirements in 10 CFR 1021.410 (b): (See full text in regulation.)

A. The proposed action fits within a class of actions that is listed in Appendix A or B to Subpart D.

For classes of actions listed in Appendix B, the following conditions are integral elements; i.e., to fit within a class, the proposal must not:

- A. Threaten a violation of applicable statutory, regulatory, or permit requirements for environment, safety and health, including DOE and/or Executive Orders;
- B. Require siting, construction, or major expansion of waste storage, disposal, recovery, or treatment facilities, but may include such categorically excluded facilities;
- C. Disturb hazardous substances, pollutants, contaminants, or CERCLA-excluded petroleum and natural gas products that pre-exist in the environment such that there would be uncontrolled or unpermitted releases; or
- D. Adversely affect environmentally sensitive resources (including but not limited to those listed in paragraph B.(4)).

B. There are no extraordinary circumstances related to the proposal that may affect the significance of the environmental effects of the proposal; and

C. The proposal is not "connected" to other actions with potentially significant impacts, and is not precluded by 40 CFR 1506.1 or 10 CFR 1021.211.

C. Determination:

Based on my review of information conveyed to me and in my possession concerning the proposed action, as NEPA Compliance Officer, I have determined that the proposed action fits within the specified class of actions, the other regulatory requirements set forth above are met, and the proposed action is hereby categorically excluded from further NEPA review.

Signature
NEPA Compliance Officer,
Brookhaven Site Office

Date